

General BSP upgrade procedure for the FP-I4C unit and HM touch panels

(BSP = Board Support Package)

Supported devices

FP-Industry 4.0 Communicator FP-I4C and the HM touch panel series HMe, HMeX200, HMx700, HMs700.

In summary, these devices will be referred to as FP-I4C/HM in the following text.

General information

- Update duration: approx. 5min
- Be sure to make a backup of your device settings and HMWIN project data.
- For BSP version 1.3 or higher, HMWIN Studio 4.5 or higher is required.
- For BSP versions lower than 1.3, HMWIN Studio 4.0 or lower is required.
- When updating from BSP version 1.0.xxx to 1.3.xxx or higher, all data will be erased.
- Extract the files from the BSP ZIP file to an empty folder before starting the update.

Software legal notices

This product incorporates the following software:

- (1) The software is developed independently by or for Panasonic Industry Europe GmbH,
- (2) the software owned by third party and licensed to Panasonic Industry Europe GmbH,
- (3) the software licensed under the GNU General Public License, Version 2.0 (GPL V2.0),
- (4) the software licensed under the GNU LESSER General Public License, Version 2.1 (LGPL V2.1), and/or
- (5) open-source software other than the software licensed under the GPL V2.0 and/or LGPL V2.1.

The software categorized as (3) – (5) are distributed in the hope that it will be useful, but WITHOUT ANY WARRANTY, without even the implied warranty of MERCHANTABILITY or FITNESS FOR A PARTICULAR PURPOSE.

Please refer to the detailed terms and conditions thereof shown in the product settings menu. At least three (3) years from delivery of this product, Panasonic will give to any third party who contacts us at the contact information provided below, for a charge no more than our cost of physically performing source code distribution, a complete machine-readable copy of the corresponding source code covered under GPL V2.0, LGPL V2.1 or the other licenses with the obligation to do so, as well as the respective copyright notice thereof.

Contact information: plc.peweu@eu.panasonic.com

Using a USB drive (fully automatic) If it is included with the update package.

Requirements: The format of the USB flash drive must be FAT32.

Go to **System Settings > Services** and make sure **Autorun scripts from external storage** is activated.

1. Copy the contents of the BSP `autoupdate.zip` file to an empty USB flash drive.
2. Go to the folder `/src` and open the file `config` in a text editor to edit the line `CFG_ADMIN_PASSWORD="admin"`.
Change "admin" to your password of the device.
3. Connect the USB flash drive to your device and wait until the update process is completed.
The unit's LEDs help you monitor the process:
 - When the USB flash drive is connected, the USR-LED starts blinking (200ms on and 200ms off) for the next 5 minutes) and MEM starts flashing spontaneously.
 - When the process is completed successfully, USR changes to static on.
 - In case of error, USR changes to blink more slowly (2s on and 500ms off). Remove the flash drive and connect it to your PC to read the log file stored in the device.
 - After completion or in case of error, reboot the power-cycle of the device.

Note that this process resets the system settings including the network settings to factory settings. Therefore, you may be required to update the IP address of your device (especially if a fixed IP address is used). Make sure the computer is in the same network as your device.

Using HMWIN Studio

1. Go to **Run > Manage Target**
2. Select the **Board** tab.
3. Click **Folder** to select the folder on your PC containing the unzipped files.
All available components are displayed in the table. You can deactivate unneeded components.
4. Select **Download** to transfer the components to the device.
You have now successfully installed the desired version.

Using a Web browser

1. Unzip the BSP ZIP file.
2. Open your browser and enter the URL `https://[IP address]/machine_config`.
Replace [IP address] with the IP address of your device.
3. Go to **Management**.
To install a component, expand it, select **Update**, drag the files into your browser, and follow the instructions.

Install the components in the following order:

Bootloader (if it is present in the ZIP file) → Config OS → Main OS

Using Corvina

Do not use this method when updating from version 1.0.xxx to version 1.3.xxx or higher because all data on the device will be erased, including the network settings.

For all other updates, you can simply connect to your FP-I4C/HM-panel unit via Corvina and follow the update instructions using a Web browser.

After installation

After updating the BSP from version 1.0.xxx to version 1.3.xxx or higher, you may need to set a new password. This is the case if your old password is considered insecure by the password rules of the new version.

Important for FP-I4C unit (for BSP updates from 1.0.xxx to version 1.3.xxx or higher)

To reinstall the application settings, you must download the firmware update files version 1.4.5.0 or higher. The update files can be downloaded from the [Panasonic InfoHub](#).

1. Check if the file 'package.zip' exists. The '.md5' file is not needed.
2. Open your browser and enter the URL `https://[IP address]/machine_config`.
Replace [IP address] with the IP address of your device.
3. Go to **System Settings > Applications** and select **App Management**.
4. Click on **Install/Update+** and select the file package.zip.
The application settings are now installed. The FP-I4C unit reboots automatically after the installation.